



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

June 1, 2010

In reply refer to:
374299:oosibodu

Mr. Ken Pintus
Lilac Enterprise Corporation
Hideaway Lake Mobile Home Estates
13076 Falcon Place
Chino, CA 91710

Dear Mr. Pintus:

SUBJECT: REVIEW OF MONITORING REPORTS FOR HIDEAWAY LAKE MOBILE HOME ESTATES

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the January-June and July-December 2009 semi annual monitoring reports, and the January-December 2009 annual monitoring report submitted by Lilac Enterprise Corporation in accordance with Order No. 93-27.

The following violations of Order No. 93-27 were identified in the submitted reports:

1. The monthly average discharge specifications for biological oxygen demand and total suspended solids established at 30 milligrams per liter (mg/L) were exceeded on November 5, 2009 with reported values of 32 and 42 mg/L.
2. The daily discharge specification for iron established at 0.3 milligrams per liter (mg/L) was exceeded on November 5, 2009 with a reported value of 0.33 mg/L.
3. The daily discharge specification for boron established at 0.5 milligrams per liter (mg/L) was exceeded on August 18, September 16, and November 5, 2009 with reported values of 0.54, 0.63, and 0.66 mg/L respectively.

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution

¹ Under authority of California Water Code section 13350.

California Environmental Protection Agency



01000000

Mr. Pintus
Hideaway Lake Mobile Home Estate

- 2 -

June 1, 2010

The next monitoring report required to be submitted is the January-June 2010 semiannual monitoring report, which is due by July 30, 2010.

In the subject line of any response, please include the requested "in reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Mr. Fisayo Osibodu at (858)-637-5594 or via email at oosibodu@waterboards.ca.gov.

Sincerely,

Robert Morris

Robert W. Morris, P.E
Senior WRC Engineer
Groundwater Basins Branch

Reg Measure ID: 374299

Violation IDs: 1) 871660, 871662 2) 871663 3) 871665, 871666, 871667

cc: Mr. Wes Fromlath, Water Quality Specialists of San Diego, 917 Seph Way, Escondido, CA
92027-3926

California Environmental Protection Agency

 Recycled Paper

CHONN